



For Vent Wiring or controller/thermostat connections, see literature packet or go to [www.bardhvac.com](http://www.bardhvac.com)

460-60-3  
Per Nameplate L1 L2 L3  
Hi Voltage  
Field Connections

R Vent option only

Ground Lug (11)

Ground Eyelet Green

Purple/White  
Black/White

3-Way Valve

Yellow  
Black  
Red

Compressor

Green  
Blue  
Yellow

Brown  
Black

Outdoor Fan Motor

Black

Black

Black

Low Ambient Control (opt.)

Red  
Red

Hi Press. Control

Blue  
Blue

Low Press. Control

Purple  
Yellow/White

Yellow  
Yellow

Outdoor Temp Switch (Opt.)

Condenser Section

**WARNING**  
USE COPPER CONDUCTORS ONLY SUITABLE FOR AT LEAST 75° C.

**DANGER**  
\*ELECTRICAL SHOCK HAZARD \*DISCONNECT POWER BEFORE SERVICING.

	Factory	Field	Optional
High Voltage			
Low Voltage			

Wire Identification numbers for Bard use only.  
**4107-306 A**

**A → A**  
Same Letter Designated Wires Connect if Option Not Used  
"A" & "C" No Control Option  
"B" Only Freeze Stat & No ODT

NOTE: JUMPER PLUG MUST BE INSTALLED WHEN NO VENT OPTION IS INSTALLED