



BARD MANUFACTURING COMPANY, INC. W12AB Series Right-Side Access Air Conditioner Engineering Specification Guide

1.0 QUALIFICATIONS

Manufacturer: Company specializing in manufacture of products specified in this section, with minimum of 5 years documented experience. Manufacturer shall have available, complete catalogue data with expanded ratings, installation and maintenance instructions.

2.0 GENERAL

Furnish and install self-contained, wall mounted air conditioner, suitable for outdoor use. Unit to be manufactured by Bard Manufacturing Company, Inc in accordance with plans. The unit shall be approved and listed by Intertek ETL Listed (ETL US/C). Unit shall be factory assembled, pre-charged, pre-wired, tested and ready to operate. The manufacturer of equipment shall be ISO 9001:2015 Certified. Unit performance shall be certified by an independent third party testing agency, in accordance with the Air Conditioning Heating and Refrigeration Institute (AHRI) Standard 390-2003 for Single Package Vertical Units. Unit cooling efficiency shall be specified by EER.

Manufacturers: Capacities shall as indicated on drawings and units shall be manufactured by Bard Manufacturing Company, Inc. or prior approved equal.

3.0 CONSTRUCTION FEATURES

3.1 Cabinet

Construction shall be a single, enclosed, weatherproof casing constructed of 20-gauge galvanized steel, stainless steel, or aluminum (chose one). Unit base is constructed of 16-gauge galvanized steel painted cabinets. Each exterior casing panel to be bonderized and finished with baked-on exterior polyester enamel paint prior to assembly. The baked-on cured paint finish shall pass the industry rub test with a minimum of 72 rubs MEK (Methyl Ethyl Ketone) or standard rub test of a minimum of 100 rubs using Toluene. Cooling section shall be fully insulated with a non – fiberglass material with heavy duty foil facing for durability and ease of cleaning. Fiberglass insulation is not acceptable. Openings shall be provided for power connections. Access openings appropriate

for outside structure to all fan motors and compressor for making repairs and for removing internal components without removing unit from its permanent installation. Fresh air intake and outdoor coil shall be protected from intrusions by a sturdy metal grating with less than 1/4 inch openings.

Colors (Select One)

Beige (standard)

White

Gray

Desert Brown

Dark Bronze

Painted cabinet construction shall be a minimum of 20 gauge Zinc coated steel, painted units shall have baked on paint, designed and tested to withstand 1000 hours of salt spray test per ASTM B117-03.

3.2 Drain Pan

Drain pan shall be constructed of 20-gauge galvanized steel, bonderized and finished with baked-on exterior polyester enamel paint.

3.3 Insulation

Insulation shall be non-fiberglass material with foil faced for ease of cleaning. Insulation materials used shall not contain fiberglass or formaldehyde.

3.4 Mounting Brackets

Full-length side mounting brackets shall be an integral part of the cabinet. Bottom mounting bracket shall be provided.

4.0 REFRIGERATION SYSTEM

All models shall use a high efficiency hermetic scroll compressor. The compressor shall be covered by a 5-year parts warranty. The refrigeration circuit shall be equipped with factory installed high and low pressure controls, suction and liquid access valves, compressor control module and liquid line filter dryer. A refrigerate metering device is included. Compressor shall be mounted on rubber grommets. Unit shall be provided with R-410A (HFC) non-ozone depleting refrigerant.

4.1 Outdoor Section

The condenser coil shall be constructed of aluminum plate fins mechanically bonded to seamless copper tubes. The condenser fan, motor and shroud shall be of slide out configuration for easy access. Condenser fan motor shall be enclosed casing with ball bearings. Open winding motors are not accepted.

4.2 Indoor Section

The evaporator coil shall be constructed of aluminum fins mechanically bonded to seamless copper tubes. Aluminum fins shall have a hydrophilic coating, to aid in condensate drainage, inhibit mold growth and protect aluminum fins from oxidation. 5 speed indoor blower motor shall be twin wheels with forward curve blades. Motor shall be high efficiency ECM with overload protection.

5.0 ELECTRICAL COMPONENTS

Electrical components are easily accessible for routine inspection and maintenance through front service panels. Circuit breaker is standard on all 208/230-volt models equipped with electric heat. Circuit breaker disconnect access is through lockable access panel.

5.1 Control Circuit

The internal control circuit shall consist of a current limiting 24VAC type transformer with resettable circuit. Auto reset high pressure switch and auto reset low pressure switch shall be standard, compressor control module with adjustable voltage protection and adjustable delay on make and break shall be standard. To prevent rapid compressor short cycling, a five minute time delay circuit shall be factory installed. A low-pressure bypass shall be factory installed to prevent nuisance tripping during low temperature start-up.

6.0 COOLING OPTIONS

6.1 Standard Cooling

The air conditioner shall function with standard cooling sensible and latent capacities.

6.2 Balanced Climate™

The air conditioner shall function with enhanced latent capacity when BALANCED CLIMATE™ cooling mode is enabled. Unit shall include Y1 and Y2 low voltage terminal connections. A 2 stage thermostat shall be capable of operating balanced Climate. Stage 1 cooling will operate with a preprogrammed and fully tested reduced fan speed. The reduction in fan speed increases latent capacity and reduces sensible capacity for increased runtime and increased latent capacity. If the 2 stage thermostat calls for second stage cooling, the unit shall shift to high speed blower and standard operation. Balanced Climate is achieved with a single stage compressor. Expanded rating in balanced climate mode shall be provided at time of submittal, and full factory performance data shall be available upon request. .

7.0 HEATING OPTIONS (Select One)

7.1 None

7.2 Electric Heat

The air conditioner shall have a factory electric resistance heater available, designed specifically for application in the W12AB Series air conditioner. Heater shall include automatic limit safety controls.

8.0 VENTILATION OPTIONS (Select One)

W12AB models are designed to provide optional ventilation packages to meet all of your ventilation and indoor air quality requirements. All ventilation packages are factory or field installed, and easily removable for service.

Units shall include an independent ventilation low voltage terminal connection, allowing for a independent 24v signal provided by controls to operate the ventilation package. No additional field installed relays shall be required to provide independent ventilation. Ventilation shall be deenergized during unoccupied hours unless otherwise specified. Only one ventilation package shall be provide and must be specified

8.1 Barometric Fresh Air Damper (X)

Damper provided with multiple pin positions, each pin position shall allow damper to open to that pin, whenever the supply blower is energized. The will fall shut when supply fan is deenergized.

Damper shall be shipped in closed position. No exhaust path is provided in the unit. If no ventilation package is specified, this option shall be provided.

8.2 Blank Off Plate (B)

OPTIONAL

A blank off plate covers the air inlet openings that restrict any outside air from entering the unit. The blank off plate should be utilized in applications where outside air is not required to be mixed with the conditioned air.

**8.3 Commercial Room Ventilator –
Modulating damper control**

(V)

OPTIONAL

The built-in commercial room ventilator is internally mounted and allows outside ventilation air, up to 50% of the total air flow rating of the unit, to be introduced through the air inlet openings. It includes a

built-in exhaust air damper. The damper shall accept a 24v on/off signal, 0-10v signal for modulation based on control input. Unit complies with ANSI/ASHRAE Standard 62.1 Ventilation for Acceptable Air Quality.

8.4 Economizer

OPTIONAL

The Economizer is internally mounted and allows outside air to be used for free-cooling when temperature and humidity conditions are favorable. The amount of exhaust air varies in response to the system controls and settings defined by the user. It includes a built in exhaust air damper. The economizer is designed to provide free cooling when outside conditions are cool and dry enough to satisfy cooling requirements without operating the compressor, providing lower operating costs while extending the life of the compressor.

Standard Features:

- Fully modulating
- Honeywell hi-torque 44 lb.-in. actuator
- Simple single blade design
- Positive shut-off with non-stick gaskets
- Electronic Enthalpy sensor
- Honeywell JADE electronic economizer module with precision settings and diagnostics

9.0 FILTER OPTIONS - (Select One)

Filters shall be Minimum Efficiency Reporting Value of MERV 8 per ASHRAE standard 52.2. Filters shall be readily available commercial sizes

9.1 1" Fiberglass

9.2 2" Pleated – MERV 8

9.3 1" Washable

10.0 UNIT CONTROL OPTIONS

10.1 Low ambient control

10.2 Alarm Relay

11.0 OPERATING CONTROLS (Field Installed)

11.1 None

11.2 Electronic non-programmable, manual/auto changeover

11.3 Electronic programmable, auto changeover

12.0 INSTALLATION

12.1 Installation shall be done in strict adherence to Bard's Installation Instructions.

13.0 WARRANTY

The Bard product specified shall be free from defects in materials and workmanship for a period of 5 years for compressor, and for a period of 5 years for all parts. Warranty period shall start from date of installation as stated on warranty card; or from date of shipment if no warranty card is returned to Bard Manufacturing. Equipment must be used under normal conditions and warranty is subject to Bard Manufacturing's standard limited warranty statement.