



T874C1000 Thermostat
 Q674A1001 Subbase
 or
 T872C1004 Thermostat
 Q672A1005 Subbase

NEC Class 2
 24V Wiring

⚠ Add jumper Rc to Rh. Set heat anticipators at .40A.

Fused
 Disconnect
 Switch

USE COPPER OR
 ALUMINUM WIRE

230/208V 60 Hz 3-Ph

Model
 P36A4
 w/12 or 15Kw

ory Wiring ———
 eic Wiring - - - -