



⚠ See alternate thermostat sheet.
Set heat anticipator at .40A.

Single Package
Air Conditioner
4 and 5 Ton
w/10kw

Fused
Disconnect
Switch

USE COPPER OR
ALUMINUM WIRE

230/208V 60 Hz 1-Ph

dry Wiring _____
field Wiring - - - - -