



T872C1004 Thermostat
Q672A1005 Subbase Δ

NEC Class 2
24V Wiring

24V Terminal
Block

Outdoor
Motor

10/370V
Capacitor

6/370V Capacitor

Blower
Relay

Indoor Motor

Transformer

Heater
Contactors

Limit

Thermal
Cut-offs

Electric
Heaters

LL3 LL2 LL1 Neut. Equip. Ground

Fused
Disconnect
Switch

USE COPPER OR
ALUMINUM WIRE

415/380-50-3

- Δ 1 Add jumper Rc to Rh. Set heat anticipators at .40A.
- Δ 2 Remove jumper for 2-stage heat.
- Δ 3 Set heat anticipators for W1 and W2 at .40A.

Single Package
Air Conditioner
4 and 5 Ton
w/9 Kw @ 415 Volt

Factory Wiring ———
Field Wiring - - - -