



T874C1004 Thermostat
Q674A1001 Subbase

or

T872C1004 Thermostat
G672A1005 Subbase 3

NEC Class 2
24V Wiring

Immersion
Crankcase
Heater

Compressor

Internal
Overload

Hi-Press. Sw. 24V Terminal
Block

Outdoor
Motor

Compressor
Contactor

10/370V
Capacitor

10/370V Capacitor

Blower
Relay

Indoor
Motor

Transformer

Limit

Heater
Contactors

Thermal
Cut-offs

Electric
Heaters

Equip.
Ground

Fused
Disconnect
Switch

USE COPPER OR
ALUMINUM WIRE

- 1 Add jumper Rc to Rh. Set heat anticipators at .40A.
- 2 Remove jumper for 2-stage heat.
- 3 Set heat anticipators for W1 and W2 at .40A.

Single Package
Air Conditioner
4 and 5 Ton
/4.5, 6, 7.5, 9kw #415V

415/380-50-3

Factory Wiring _____
Field Wiring - - - - -