



⚠ Set heat anticipator at .40A.

- NOTE A: 4 Ton Capacitor - 15/370V
 5 Ton Capacitor - 7 $\frac{1}{2}$ /370V
- NOTE B: 4 Ton Capacitor - 40/440V
 5 Ton Capacitor - 45/440V

Single Package
 Air Conditioner
 4 and 5 Ton
 w/10Kw

USE COPPER OR
 ALUMINUM WIRE

Fused
 Disconnect
 Switch

230/208V 60 Hz 1-Ph

Factory Wiring ———
 Field Wiring - - - - -