



Emergency Signal Light

T872C1004 Thermostat
Q672F1026 Subbase

(X2) (X1) (G) (R) (Y) (W1) (E) (W2)

NEC Class 2
24V Wiring

Defrost
Thermostat

- 1 3-terminal capacitor provides off-cycle crankcase heat.
- 2 Set heat anticipators at .40A for W1 and W2.
- 3 Reroute jumper from X2-W2 to X2-E.

USE COPPER OR ALUMINUM WIRE

Factory Wiring ———
Field Wiring - - - - -

Single Package Heat Pump
2 and 2-1/2 Ton
One Motor
w/8 or 10kw

230V 60 Hz 1-Ph