



NBC Class 2
24V Wiring

- ⚠ Set heat anticipators at .40A for W1 and W2.
- ⚠ Reroute jumper from X2-W2 to X2-E.

Fused Disconnect Switch

USE COPPER OR ALUMINUM WIRE

Single Package Heat Pump
2 and 2-1/2 Ton
One Motor
w/9Kw Heater

230V 60 Hz 3-Ph

Factory Wiring ———
Field Wiring - - - - -