



Defrost  
Thermostat

- ⚠ 1 3-terminal capacitor provides off-cycle crankcase heat.
- ⚠ 2 Set heat anticipators at .40A for W1 and W2.
- ⚠ 3 Reroute jumper from X2-W2 to X2-E.

Fused  
Disconnect  
Switch

USE COPPER OR  
ALUMINUM WIRE

240/220-50-1

Factory Wiring  
Field Wiring

Single Package Heat Pump  
2 and 2-1/2 Ton  
One Motor  
w/5Kw

4003-420 Rev. B