



- ⚠ 1 3-terminal capacitor provides off-cycle crankcase heat.
- ⚠ 2 Set heat anticipators at .40A for W1 and W2.
- ⚠ 3 Reroute jumper from X2-W2 to X2-E.

USE COPPER OR ALUMINUM WIRE

Single Package Heat Pump  
2 and 2-1/2 Ton  
One Motor  
w/5Kw

Fused Disconnect Switch

240/220-50-1

Factory Wiring ———  
Field Wiring - - - - -

4003-420C