



- ⚠ Set heat anticipators at .40A
- ⚠ Reroute jumper from X2-W2 to X2-E.

USE COPPER OR ALUMINUM WIRE

Factory Wiring ———
Field Wiring - - - - -

Single Package
Heat Pump
3-Ton
w/6.75, 9, 11.25kw

Fused Disconnect Switch

415/380-50-3

Rev. C
4005-620