



Emergency Signal Light

T872C1004 Thermostat  
Q672F1026 Subbase

NEC Class 2  
24V Wiring

24V  
Terminal  
Block

Transformer

Hi-Press. Sw

Changeover  
Relay

10/370V  
Capacitor

Em. Heat Relay

Reversing  
Valve

6/370V  
Capacitor

Limit

Defrost  
Relay

Outdoor  
Motor

Blower  
Relay

Indoor  
Motor

Heater  
Contactors

Timer

230V  
Terminal  
Blocks

Ckt. A

Ckt. B

Equip.  
Ground

Ckt. A

Fused  
Disconnect  
Switch

Ckt. B

USE COPPER OR  
ALUMINUM WIRE

- ① Reroute jumper from X2-W2 to X2-E.
- ② Set heat anticipators at .40A for W1 and .80A for W2. See note 3.
- ③ Remove this jumper if 3rd stage heat outdoor thermostat is used and set W2 heat anticipator to .40A. See Typical Installation Instructions.

Single Package  
Heat Pump  
4 and 5 Ton  
w/18kw

