



CHART A

MODEL	CAPACITOR
20WA2	30/370
24WA5	35/370

⚠ T87F or 1F56
Thermostat

NEC Class 2
24V Wiring

Run
Capacitor
(see chart A)

5/370 Capacitor

Compressor
Contactor

Outdoor Motor

208V Transformer

24V
Terminal
Block

Blower
Relay

7.5/370
Capacitor

Indoor
Motor

Limit

CIRCUIT
BREAKER

Equip.
Ground

Heater
Contactor

Thermal
Cut-off

Electric
Heater

**USE COPPER OR
ALUMINUM WIRE**

⚠ See alternate thermostat sheet. Set heat
anticipator at .40A.

⚠ For 208V operation move this
wire to 208V transformer tap.

⚠

MODEL	KW	CIRCUIT BREAKER
20WA2	4	25A
20WA2	5	30A
24WA5	4, 5	30A

MODEL
20WA2, 24WA5
W/4 or 5 KW

FACTORY WIRING	FIELD WIRING
Low Voltage ———	-----
High Voltage ———	-----

230/208-60-1