



USE COPPER OR ALUMINUM WIRE

- ▲ See alternate thermostat sheet. Set heat anticipator at .40A.
- ▲ For 208V operation move this wire to 208V transformer tap.

MODEL
24WA4
w/ 8
OR 10KW

230/208-60-1