



USE COPPER OR ALUMINUM WIRE

⚠ See alternate thermostat sheet. Set heat anticipator at .40A.

⚠ For 208V operation move this wire to 208V transformer tap.

230/208-60-1

MODEL
24WA4
w/ 8
OR 10KW

4007-135