



USE COPPER CONDUCTORS ONLY

- ⚠ See alternate thermostat sheet.
- ⚠ For 208V operation move this wire to 208V transformer tap.

Fused Disconnect Switch

240/270-50-1

FACTORY WIRING	FIELD WIRING
Low Voltage ———	—————
High Voltage ———	—————