



8201-042
3-Minute
Time
Delay

15/10-370V
Run
Capacitor

Low Ambient Control
CO @ 200 PSIG
CI @ 250 PSIG

T874D Thermostat
Q674A1001 Subbase

Rc Rh G Y1 Y2 W1 W2

24V
Terminal
Block

Outdoor
Motor

24V Transformer

Blower
Relay

7.5/370
Capacitor

Indoor
Motor

8201-042
3-Minute
Time Delay

Limit

Heater
Contactor

Equip.
Ground

240V Terminal Block

Thermal
Cut-off

Electric
Heater

LL3

LL1

USE COPPER OR
ALUMINUM WIRE

Fused
Disconnect
Switch

230/208-60-1

- 1 Capacitor provides off-cycle crankcase heat.
- 2 Set heat anticipator at .40A.
- 3 Do not connect jumper until transformer phasing has been checked. Refer to Step 8 on page 5 of 2100-084 also see diagram 7 on page 16.
- 4 For 208V operation move this wire to 208V transformer tap.

Model/Cat.No.
24WA2/05A20
Unit 1 of 2

Factory Wiring _____
Field Wiring - - - - -