



USE COPPER OR ALUMINUM WIRE

- ⚠ See alternate thermostat sheet. Set heat anticipator at .40A.
- ⚠ For 208V operation move this wire to 208V transformer tap.

230/208-60-1

MODELS
24WA4
w/4 or 5Kw

Factory Wiring ———
Field Wiring - - - - -

4007-838A