



5-Minute
Anti-Cycle
Relay

Equip.
Ground

230/208-60-1

USE COPPER OR
ALUMINUM WIRE

Fused
Disconnect
Switch

- ⚠ See alternate thermostat sheet. Set heat anticipator at .40A.
- ⚠ For 208V operation move this wire to 208V transformer tap.

MODELS
24WA4
w/4 or 5Kw

Factory Wiring ———
Field Wiring - - - - -

4007-846 A