



- ⚠ If there is an X1 and X2 terminal on Q674L1181 jumper them together and connect from C to either one.
- ⚠ For 208V operation move this wire to 208V transformer tap.

Used Disconnect Switch

USE COPPER OR ALUMINUM WIRE

FACTORY WIRING	FIELD WIRING
Low Voltage ———	—————
High Voltage ———	—————