



T872R1164/0672L1185
or
T874R1129/0674L1181

40/440 Capacitor

Compressor Fault Relay

COMPRESSOR CONTACTOR

Transformer

208V 24V

High-Pressure Switch

Reversing Valve Solenoid (24V)

Blower Relay

Em. Heat Relay

Defrost Relay

Capacitor 15/370

OUTDOOR MOTOR

Defrost Thermostat

Defrost Timer

LIMIT

Heating Blower Relay

HIGH (BLACK)

LOW (RED)

Indoor Motor

10/370 Capacitor

Heater Contactors

50A Circuit Breaker (42WH)

50A Circuit Breaker (48WH5)

60A Circuit Breakers

Thermal Cutoff

Electric Heater

EQUIP. GROUND

⚠ If there is an X1 and X2 terminal on Q674L1181, jumper them together and connect from C to either one

	FACTORY WIRING	FIELD WIRING
Low Voltage	—	- - - -
High Voltage	- - - -	—

USE COPPER OR ALUMINUM WIRE

⚠ For 208V operation move this wire to 208V transformer tap.