



T872N1036/Q672F1299 or T874N1024/Q674F1261

X G R Y1 W1 W2 W3 E L

T872R1164/Q672L1185  
T874R1129/Q674L1181

X2 X1 G R Y1 B W2 W3 E L

C G R Y1 Y1 B W1 W2 W3 E L D1 D1

24V Terminal Block

Compressor Contactor

Transformer

High Pressure Switch

Blower Relay

Defrost Relay

Black HIGH

Reversing Valve Solenoid (24V)

Capacitor 15/370

Outdoor Motor

10/370 Capacitor

LOW (P.O.) Indoor Motor

Defrost Thermostat

Defrost Timer

Terminal Block

Equip. Ground

LL3 LL2 LL1

Fused Disconnect Switch

230/208-60-3

USE COPPER OR ALUMINUM WIRE

	FACTORY WIRING	FIELD WIRING
Low Voltage	—————	- - - - -
High Voltage	—————	—————

⚠ If there is an X1 and X2 terminal on Q674L1181, jumper them together and connect from C to either one.

⚠ For 208V operation move this wire to 208V transformer tap 4014-210N