



T872N1036/Q672F1299 or T874N1024/Q674F1261

T872R1164/Q672L1185
or
T874R1129/Q674L1181

24V
Terminal
Block

USE COPPER OR ALUMINUM WIRE

CKTA

230/208-60-3

Equip. Ground

⚠ If there is an X1 and X2 terminal on Q674L1181 jumper them together and connect from C to either one.

⚠ For 208V operation move this wire to 208V transformer tap.

FACTORY WIRING	FIELD WIRING
Low Voltage ———	-----
High Voltage - - - - -	-----

MODEL
42WH-3, 48WH-3
HEAT PUMP
w/9 KW

4014-221 E