



T872N1036/Q672F1299 or T874N1024/Q674F1261

T872R1164/Q672L1185
or
T874R1129/Q674L1181

24V Terminal Block

208V 24V Transformer

High Pressure Switch

Blower Relay

Reversing Valve Solenoid (24V)

Defrost Relay

Capacitor 15/370

Outdoor Motor

Defrost Thermostat

HIGH (Black)

(Red) LOW

Indoor Motor

10/370 Capacitor

Limit

Heater Contactor

Defrost Timer

(See Chart A) Fuse Panel

Thermal Cutoff

Electric Heater

Equip. Ground

230/208-60-3

| CHART A | | |
|---------|-----------------------|----------|
| Fuse A | 42NH-3 | 48NH5-3 |
| Fuse B | 40A T.D. | 45A T.D. |
| Fuse A | 40A Standard for 12Kw | |
| Fuse B | 45A Standard for 18Kw | |

ALL FUSES CLASS K5

⚠ If there is an X1 and X2 terminal on Q674L1181, jumper them together and connect from C to either one.
⚠ For 208V operation move this wire to 208V transformer tap.

MODEL
42NH-3, 43NH5-3
HEAT PUMP
w/12, 15 Kw

USE COPPER OR ALUMINUM WIRE

FACTORY WIRING FIELD WIRING
Low Voltage _____
High Voltage - - - - -

4014-230 S