



T872N1036/Q672F1299 or T874N1024/Q674F1261

T872R1164/Q672L1185
or
T874R1129/Q674L1181

24V Terminal Block

Transformer

208V

24V

High Pressure Switch

Blower Relay

Defrost Relay

Outdoor Motor

Capacitor 15/370

Heating Blower Relay

Indoor Motor

Reversing Valve Solenoid (24V)

Defrost Thermostat

Defrost Timer

Limit

Heater Contactor

(See Chart A) Fuse Panel

YELLOW

ELECTRIC HEATER

Equip. Ground

THERMAL CUT-OFF YELLOW

⚠ If there is an X1 and X2 terminal on Q674L1181, jumper them together and connect from C to either one.

USE COPPER OR ALUMINUM WIRE

| CHART A | |
|---------|--------------------------------|
| Fuse A | 42WH-3 48WH5-3 |
| Fuse B | 40A T.D. 45A T.D. 60A Standard |

ALL FUSES CLASS K5

FACTORY WIRING FIELD WIRING
 Low Voltage ———
 High Voltage - - - -

230/208-60-3

⚠ For 208V operation move this wire to 208V transformer tap.

4014-240 W