



T872n1036/Q672F1299 or T874N1024/Q674F1261

T872R1164/Q672L1185
T874R1129/Q674L1181

24V Terminal Block

Transformer
208V 24V

High Pressure Switch

Blower Relay

Em. Heat Relay

Defrost Relay

Outdoor Motor

Capacitor 15/370

Heating Blower Relay

10/370 Capacitor

Indoor Motor

Limit

Heater Contactor

Thermal Cut-off

Electric Heater

Reversing Valve Solenoid (24V)

Defrost Thermostat

Defrost Timer

40A Circuit Breaker (42WH-3)

45A Circuit Breaker (48WH5-3)

60A Circuit Breaker

Equip. Ground

CKT. A

CKT. B

USE COPPER OR ALUMINUM WIRE

230/208-60-3

FACTORY WIRING FIELD WIRING
Low Voltage High Voltage

MODEL
42WH-3, 48WH5-3
HEAT PUMP
w/18KW

For 208V operation move this wire to 208V transformer tap.

40A-241B