



TB72N1035/Q672F1299
or
TB74N1024/Q674F1261

TB72R1164/Q672C1185
or
TB74R1129/Q674L1181

24V
Terminal
Block

230V Terminal
Block

230
460
Transformer

Terminal
Block
LL3 LL2 LL1

Equip.
Ground

⚠ If there is an X1 and X2 terminal on Q674L1181, jumper them together and connect from C to either one.

MODEL
48WH2
HEAT PUMP
0 Kw

Fused
Disconnect
Switch

460-60-3

FACTORY WIRING	FIELD WIRING
Low Voltage ———	-----
High Voltage ———	-----

4014-310F