



X G R Y1 W1 W2 W3 E L T872N1036/0672F1299  
or  
T874N1024/0674F1261

X2 X1 G R Y1 B W2 W3 E L T872R1184/0672L1185  
or  
T874R1129/0674L1181

24V  
Terminal  
Block

230V Terminal  
Block

230

460

Transformer

Terminal  
Block

LL3 LL2 LL1

Equip.  
Ground

Fused  
Disconnect  
Switch

860-60-3

USE COPPER OR  
ALUMINUM WIRE

⚠ If there is an X1 and X2 terminal on Q674L1181, jumper them together and connect from C to either one.

⚠ For 208V operation move this wire to 208V transformer tap.

FACTORY WIRING	FIELD WIRING
Low Voltage _____	Low Voltage _____
High Voltage _____	High Voltage _____

MODELS  
42WH-3, 48WH5-3  
Heat Pump  
0 KW

401A-310L