



X G R Y1 W1 W2 W3 E L T872N1036/Q672F1299
OR
T874N1024/Q674F1261

X2 X1 G R Y1 B W2 W3 E L T872R1164/Q672L1185
OR
T874R1129/Q674L1181

C G R Y1 Y1 B W1 W2 W3 E L OH O1

24V Terminal Block

230V Terminal Block

230

Transformer

460

Terminal Block

LL3 LL2 LL1

Fused Disconnect Switch

460-60-3

USE COPPER OR ALUMINUM WIRE

⚠ If there is an X1 and X2 terminal on Q674L1181, Jumper them together and connect from C to either one.

⚠ For 208V operation move this wire to 208V transformer tap.

FACTORY WIRING	FIELD WIRING
Low Voltage	-----
High Voltage	-----

MODEL
48WH2, 48WH5
HEAT PUMP
9, 12, 15 Kw

4014-320N