



X G R Y1 W1 W2 W3 E L T872N1036/Q672F1299  
or  
T874N1024/Q674F1261

X2 X1 G R Y1 B W2 W3 E L T872R1164/Q672L1185  
or  
T874R1129/Q674L1181

C G R Y1 B W1 W2 W3 E L DH D1

24V Terminal Block  
Outdoor Thermostat

230V Terminal Block  
230  
Transformer  
460

MODEL  
48WH2, 48WH5  
HEAT PUMP  
9, 12, 15 Kw

⚠ If there is an X1 and X2 terminal on Q674L1181, Jumper them together and connect from C to either one.

⚠ For 208V operation move this wire to 208V transformer tap.

FACTORY WIRING	FIELD WIRING
Low Voltage _____	_____
High Voltage _____	_____

⚠ Factory set at 20°F. May be readjusted in field if necessary.

Fused Disconnect Switch

460-60-3

USE COPPER OR ALUMINUM WIRE

4014-804E