



T872N1036/Q672F1299 or T874N1024/Q674F1261

T872R1164/Q672L1185
T874R11297/Q674L1181

24V Terminal Block

Compressor Contactor

Transformer

208V

24V

High Pressure Switch

Blower Relay

HIGH (Black)

LOW (Red)

Indoor Motor

10/370 Capacitor

Defrost Relay

Capacitor 15/370

Outdoor Motor

Limit

Heater Contactor

Thermal Cutoff

Electric Heater

Reversing Valve Solenoid (24V)

Defrost Thermostat

Defrost Timer

Fuse Panel

Equip. Ground

Fuse A - 45A Time Delay
Fuse B - 40A STD 12Kw,
45A STD 15Kw

⚠ If there is an X1 and X2 terminal on Q674L1181, jumper them together and connect from C to either one.
⚠ For 208V operation move this wire to 208V transformer tap.

MODEL 48WH5 w/12, 15Kw

230/208-60-5

FACTORY WIRING - FIELD WIRING
Low Voltage ————
High Voltage ————

USE COPPER OR ALUMINUM WIRE

4014-809 B