



5 Minute
Time Delay
Relay

Terminal
Block

Terminal
Block

USE COPPER OR
ALUMINUM WIRE

IF there is an X1 and X2 terminal on 0674L1181,
 jumper them together and connect from C to either one.

For 208V operation use this
 wire to 208V tap on transformer top.

FACTORY WIRING
Low Voltage
High Voltage

MODELS
48WHS-3
Heat Pump
9, 12, 15 kW