

⚠ If there is an X1 and X2 terminal on Q674L1181, jumper them together and connect from C to either one.

⚠ Outdoor thermostat factory set at 25°

⚠ For 208V operation move this wire to 208V transformer tap.

