



230V Terminal Block

LL3 LL1

Ckt. A

Equip. Ground

Fused Disconnect Switch

230/208-60-1

USE COPPER OR ALUMINUM WIRE

	FACTORY WIRING	FIELD WIRING
Low Voltage	————	- - - -
High Voltage	————	- - - -

- ① MU36C - 40/370 CAP.
MU42D - 40/440 CAP.
- ② Remove jumper for two stage heat.
- ③ Required only for use with optional EH3MA-1-15A and EH3MA-1-20A Heat Packages.
- ④ Not required when no optional heat packages are used.

T872C1004 Thermostat
Q672A1005 Subbase

T87F/Q539 or 1F56
Thermostat

G R Y W1 W2
Rh G Rc Y W

C G R Y W1 W2 E F
24V Terminal Block

Blower Relay

Indoor Motor

5/370V Capacitor

6 Pin Connector for Optional Electric Heat Package

MODELS
MU36C, MU42D