



TIME
DELAY
RELAY

EQUIPMENT
GROUND

LL3 LL1

TERMINAL
BLOCK

FUSED
DISCONNECT
SWITCH

230/208V 60HZ 1-PH
240/220V 50HZ 1-PH
PER NAMEPLATE

- ⚠ NOT REQUIRED WHEN OPTIONAL HEAT PACKAGES ARE NOT INSTALLED
- ⚠ FOR 208V OPERATION MOVE THIS WIRE TO 208V TRANSFORMER TAP.

⚠

MODEL NO.	CAPACITOR
P1130A1	35/5-370
P1136A1	35/5-370

	FACTORY WIRING	FIELD WIRING
LOW VOLTAGE	_____	-----
HIGH VOLTAGE	_____	-----

USE COPPER OR
ALUMINUM WIRE