



### COMPONENT CODE

CB	CIRCUIT BREAKER
COMP	COMPRESSOR
CCM	COMPRESSOR CONTACTOR
CC	COMP. CONTROL MODULE
CR1	CONTROL RELAY #1
CR2	CONTROL RELAY #2
CR3	CONTROL RELAY #3
FCB	FURNACE CONTROL BOARD
FR	FLAME ROLLOUT
FS	FLAME SENSOR
FT	FREEZE THERMOSTAT
GND	GROUND
GV	GAS VALVE
HPC	HIGH PRESSURE CONTROL
IBC	INDOOR BLOWER CAPACITOR
IBM	INDOOR BLOWER MOTOR
IDB	INDUCED DRAFT BLOWER
LPC	LOW PRESSURE CONTROL
OFC	OUTDOOR FAN CAPACITOR
ODM	OUTDOOR FAN MOTOR
PL1	2 PIN PLUG
PM	PHASE MONITOR
PRL	PRIMARY LIMIT
PS	PRESSURE SWITCH
RAT	RETURN AIR THERMOSTAT
SI	SPARK IGNITER
SL	SECONDARY LIMIT
SV	SOLENOID VALVE
T	TRANSFORMER
TDR1	TIME DELAY RELAY #1
TDR2	TIME DELAY RELAY #2
TS	TERMINAL STRIP

### COLOR CODE

BK	BLACK
BL	BLUE
BR	BROWN
GR	GRAY
OR	ORANGE
PR	PURPLE
R	RED
W	WHITE
Y	YELLOW

USE COPPER OR ALUMINUM WIRE

### BLOWER SPEED COLOR CODE

HIGH	BLACK
MEDIUM HIGH	BLUE
MEDIUM LOW	PURPLE
LOW	RED
AUX.	ORANGE

**⚠ DANGER**  
\* ELECTRIC SHOCK HAZARD  
\* DISCONNECT POWER BEFORE SERVICING

**⚠** LABELED WIRES CONNECT IF NO OPTIONS USED

### WIRING CODE

230/208 VAC	FACTORY	—————
230/208 VAC	FIELD	-----
24 VAC	FACTORY	—————
24 VAC	FIELD	-----

MODEL	COOL	HEAT	C. BREAKER
WG241	RED	MED. HIGH	20A

**⚠** RED (LOW), PURPLE (MED. LOW)  
BLUE (MED. HIGH), BLACK (HIGH)  
WHERE APPLICABLE.  
ALL UNUSED LEADS TAPED OFF.

IF ANY OF THE ORIGINAL WIRE AS SUPPLIED WITH THE APPLIANCE MUST BE REPLACED, IT MUST BE REPLACED WITH WIRING MATERIAL HAVING A TEMPERATURE RATING OF AT LEAST 105°C EXCEPT THE IGNITION CABLE WHICH IS 250° HIGH VOLTAGE CABLE.