



USE COPPER CONDUCTORS  
ONLY SUITABLE FOR AT  
LEAST 75° C

COMPONENT CODE			
ALR	ALARM RELAY	IBC	INDOOR BLOWER CAPACITOR
CB1	CIRCUIT BREAKER #1	IBM	INDOOR BLOWER MOTOR
CB2	CIRCUIT BREAKER #2	IBR	INDOOR BLOWER RELAY
CC	COMPRESSOR CONTACTOR	LAC	LOW AMBIENT CONTROL
CCM	COMPRESSOR CONTROL MODULE	LPC	LOW PRESSURE CONTROL
COMP	COMPRESSOR	LS	LIMIT SWITCH
DCC	DUAL CAN CAPACITOR	OFM	OUTDOOR FAN MOTOR
GND	EQUIPMENT GROUND	PL1	PLUG #1
H1	HEAT STRIP #1	SK	START KIT
H2	HEAT STRIP #2	T	TRANSFORMER
HC1	HEATER CONTACTOR #1	TB, TB2	TERMINAL BLOCK
HC2	HEATER CONTACTOR #2	TBL	LOW VOLTAGE TERMINAL BLOCK
HPC	HIGH PRESSURE CONTROL	TCO	THERMAL CUTOFF

A B LABELED WIRES CONNECT IF NO OPTIONS USED.
 
A MOVE RED WIRE TO 208V TAP FOR 208V OPERATION
 

A RED (LOW) BLUE (MED) BLACK (HIGH) WHERE APPLICABLE

	COLOR CODE							BARD MFG. CO.
	FACTORY STD.	FIELD	OPTIONAL	BK	Y	V (PR)	T	
HIGH VOLTAGE	<u>          </u>	<u>          </u>	<u>          </u>	BLACK	YELLOW	V (PR)	TAN	
LOW VOLTAGE	<u>          </u>	<u>          </u>	<u>          </u>	BROWN	GREEN	(GY)	PINK	
ACCESSORY	<u>          </u>	<u>          </u>	<u>          </u>	RED	BLUE	(S)	LAVENDER	
				ORANGE	WHITE			

4095-128 C