



230/208-60-3  
240/220-50-3  
Per Nameplate

6 Pin Plug (Female)

Evaporator Section  
230/208-60-3  
240/220-50-3  
Per Nameplate

Terminal Block #1

Compressor Contactor  
Compressor  
Outdoor Fan Capacitor  
Outdoor Fan Motor  
Low Ambient Control (Opt.)  
Terminal Block #2 (Opt.)  
Indoor Blower Relay  
Indoor Fan Motor  
Indoor Fan Capacitor

Indoor Blower Relay

Indoor Fan Capacitor  
Indoor Fan Motor  
Red (Low), Black (High) where applicable  
Ground Lug  
Terminal Block #1  
Phase Monitor  
Move Red Wire to 208V tap for 208V Operation  
Transformer  
Ground Eyelet

Compressor Control Module

Phase Monitor  
Transformer  
Ground Eyelet  
Hi Pressure Control  
Low Pressure Control  
Low Ambient Control (opt.)

Alarm Relay (Opt.)

Compressor Contactor  
Compressor  
Outdoor Fan Capacitor  
Outdoor Fan Motor  
Red (50 hz only) (Low), Black (High) where applicable

Low Voltage Terminal Block

Control Panel

Condenser Section

Transformer  
24 VAC  
6 Pin Plug (Female)  
Hi Pressure Control  
Phase Monitor  
Alarm Relay (Opt.)  
Compressor Control Module  
Compressor Contactor  
Low Pressure Control  
Indoor Blower Relay  
Low Voltage Terminal Block

Wires Connect if Option Not Used	Factory	Field	Optional
	High Voltage		
Low Voltage			

**WARNING**  
USE COPPER CONDUCTORS  
ONLY SUITABLE FOR AT LEAST  
75° C.

**DANGER**  
ELECTRICAL SHOCK HAZARD  
DISCONNECT POWER BEFORE  
SERVICING.

4095-260