

COMPONENT CODE			
ALR	ALARM RELAY	LAC	LOW AMBIENT CONTROL
CB1	CIRCUIT BREAKER #1	LBL	LINE BREAK LIMIT
CB2	CIRCUIT BREAKER #2	LPC	LOW PRESSURE CONTROL
CC	COMPRESSOR CONTACTOR	LS	LIMIT SWITCH
CCH	CRANKCASE HEATER	OFC	OUTDOOR FAN CAPACITOR
CCM	COMPRESSOR CONTROL MODULE	OFM	OUTDOOR FAN MOTOR
CHR	CRANKCASE HEATER RELAY	PM	PHASE MONITOR
COMP	COMPRESSOR	PTCR	PART TIME CAP. RELAY
FB	FUSE BLOCK	P1	ACCESSORY PLUG #1
GND	EQUIPMENT GROUND	P2	ACCESSORY PLUG #2
H1	HEAT STRIP #1	T	TRANSFORMER
H2	HEAT STRIP #2	T2	TRANSFORMER #2
HC1	HEATER CONTACTOR #1	TB	TERMINAL BLOCK
HC2	HEATER CONTACTOR #2	TB2	TERMINAL BLOCK #2
HPC	HIGH PRESSURE CONTROL	TB3	TERMINAL BLOCK #3
HSS	HIGH SPEED SOLENOID	TBL	LOW VOLTAGE TERMINAL BLOCK

A LABELED WIRES CONNECT IF NO OPTIONS USED.

B IBM TIME DELAY DISABLE

	FACTORY STD.	FIELD	OPTIONAL
HIGH VOLTAGE	———	— — —	—·—·—
LOW VOLTAGE	———	— — —	—·—·—
ACCESSORY			—··—··—

COLOR CODE									
BK	BLACK	Y	YELLOW	V	VIOLET	T	TAN	BARD MFG. CO.	
BR	BROWN	G	GREEN	(PR)	PURPLE	PK	PINK		
R	RED	BL	BLUE	GY	GRAY	L	LAVENDER	4095-341A	
O	ORANGE	W	WHITE	(S)	SLATE				