



USE CLASS 1 WIRING FOR ALL CONNECTIONS TO THE LOW VOLTAGE TERMINAL BLOCK.  
ALARM RELAY CONTACT RATINGS  
125VA @24VAC.

COMPONENT CODE			
CC	COMPRESSOR CONTACTOR	LPB	LOW PRESSURE BYPASS
COMP	COMPRESSOR	LPC	LOW PRESSURE CONTROL
GND	EQUIPMENT GROUND	LS	LIMIT SWITCH
H1	HEAT STRIP #1	OFC	OUTDOOR FAN CAPACITOR
H2	HEAT STRIP #2	OFM	OUTDOOR FAN MOTOR
HC1	HEATER CONTACTOR #1	OFR	OUTDOOR FAN RELAY
HC2	HEATER CONTACTOR #2	PD	PULL DISCONNECT
HPC	HIGH PRESSURE CONTROL	PL1	PLUG #1
IBC	INDOOR BLOWER CAPACITOR	T	TRANSFORMER
IBM	INDOOR BLOWER MOTOR	TB	TERMINAL BLOCK
IBR	INDOOR BLOWER RELAY	TBL	LOW VOLTAGE TERMINAL BLOCK
LAC	LOW AMBIENT CONTROL	TCO	THERMAL CUTOFF
LOR	LOCK OUT RELAY	TDR	TIME DELAY RELAY

⚠️ ⚠️ ⚠️ LABELED WIRES CONNECT IF NO OPTIONS USED. ⚠️ RED (LOW) BLACK (HIGH) ⚠️ MOVE RED WIRE TO 208V TAP FOR 380V OPERATION ⚠️ (BLACK) HIGH SPEED TAP NOT TO BE USED ON 50HZ MODELS

	FACTORY STD.	FIELD	OPTIONAL
HIGH VOLTAGE	————	-----	-----
LOW VOLTAGE	————	-----	-----
ACCESSORY	————	-----	-----

COLOR CODE							
BK	BLACK	Y	YELLOW	V	VIOLET	T	TAN
BR	BROWN	G	GREEN	(PR)	PURPLE	PK	PINK
R	RED	BL	BLUE	GY	GRAY	L	LAVENDER
O	ORANGE	W	WHITE	(S)	SLATE		

**BARD MFG. CO.**  
4095-614 B

