



USE COPPER CONDUCTORS ONLY  
SUITABLE FOR AT LEAST 75° C

**A**, **B** LABELED WIRES CONNECT IF NO OPTIONS USED. **C** MOVE RED WIRE TO 208V TAP FOR 208V OPERATION **D** RED (LOW) BLACK (HIGH) WHERE APPLICABLE

HIGH VOLTAGE	FACTORY STD.			FIELD			OPTIONAL			COLOR CODE				BARD MFG. CO. 4096-115 A												
	————	————	————	-----	-----	-----	-----	-----	-----	BK	BR	R	O		Y	G	BL	E	C	V	(PR)	GY	(S)	T	PK	L
LOW VOLTAGE	————	————	————	-----	-----	-----	-----	-----	-----																	
ACCESSORY	————	————	————	-----	-----	-----	-----	-----	-----																	

COMPONENT CODE	
CB1	CIRCUIT BREAKER #1
CB2	CIRCUIT BREAKER #2
CC	COMPRESSOR CONTACTOR
COMP	COMPRESSOR
DCC	DUAL CAN CAPACITOR
DFC	DEFROST CONTROL
EHR	EMERGENCY HEAT RELAY
GND	EQUIPMENT GROUND
H1	HEAT STRIP #1
H2	HEAT STRIP #2
HC1	HEATER CONTACTOR #1
HC2	HEATER CONTACTOR #2
HPC	HIGH PRESSURE CONTROL
IBC	INDOOR BLOWER CAPACITOR
IBM	INDOOR BLOWER MOTOR
IBR	INDOOR BLOWER RELAY
LAB	LOW AMBIENT BYPASS CONTROL
LAC	LOW AMBIENT CONTROL
LPB	LOW PRESSURE BYPASS
LPC	LOW PRESSURE CONTROL
LS	LIMIT SWITCH
OFM	OUTDOOR FAN MOTOR
PL1	PLUG #1
RV	REV. VALVE SOLINOID
SK	START KIT
T	TRANSFORMER
TB	TERMINAL BLOCK
TBL	LOW VOLTAGE TERMINAL BLOCK
TCO	THERMAL CUTOFF