



USE COPPER CONDUCTORS ONLY
SUITABLE FOR AT LEAST 75° C

COMPONENT CODE			
CB1	CIRCUIT BREAKER #1	ERV	ENERGY RECOVERY VENTILATOR
CB2	CIRCUIT BREAKER #2	FT	FREEZE T-STAT
CC	COMPRESSOR CONTACTOR	GND	EQUIPMENT GROUND
CCH	COMPRESSOR CRANKCASE HEATER	H1	HEAT STRIP #1
COMP	COMPRESSOR	H2	HEAT STRIP #2
CR1	CONTROL RELAY #1	HC1	HEATER CONTACTOR #1
CR2	CONTROL RELAY #2	HC2	HEATER CONTACTOR #2
CR3	CONTROL RELAY #3	HPC	HIGH PRESSURE CONTROL
CR4	CONTROL RELAY #4	IBC	INDOOR BLOWER CAPACITOR
CR5	CONTROL RELAY #5	IBM	INDOOR BLOWER MOTOR
CR6	CONTROL RELAY #6	IBR	INDOOR BLOWER RELAY
DCC	DUAL CAN CAPACITOR	LAB	LOW AMBIENT BYPASS CONTROL
DFC	DEFROST CONTROL	LAC	LOW AMBIENT CONTROL
EMR	EMERGENCY HEAT RELAY	LPB	LOW PRESSURE BYPASS
LPC	LOW PRESSURE CONTROL	LS	LIMIT SWITCH
LS	LIMIT SWITCH	OFM	OUTDOOR FAN MOTOR
OFM	OUTDOOR FAN MOTOR	PL1	PLUG #1
PL1	PLUG #1	RAT	RETURN AIR THERMOSTAT
RAT	RETURN AIR THERMOSTAT	RV	REV. VALVE SOLENOID
RV	REV. VALVE SOLENOID	SK	START KIT
SK	START KIT	T	TRANSFORMER
T	TRANSFORMER	TB	TERMINAL BLOCK
TB	TERMINAL BLOCK	TBL	LOW VOLTAGE TERMINAL BLOCK
TBL	LOW VOLTAGE TERMINAL BLOCK	TCO	THERMAL CUTOFF
TCO	THERMAL CUTOFF	TWV	THREE WAY VALVE
TWV	THREE WAY VALVE	TDR	TIME DELAY RELAY
TDR	TIME DELAY RELAY		

A, B LABELED WIRES CONNECT IF NO OPTIONS USED.
 C MOVE RED WIRE TO 208V TAP FOR 208V OPERATION
 D RED (LOW) BLACK (HIGH) WHERE APPLICABLE

		COLOR CODE								
FACTORY STD.	FIELD	OPTIONAL								
HIGH VOLTAGE	—————	-----	BK	BLACK	Y	YELLOW	V	VIOLET	T	TAN
LOW VOLTAGE	—————	-----	BR	BROWN	G	GREEN	(PR)	PURPLE	PK	PINK
ACCESSORY	—————	-----	R	RED	BL	BLUE	GY	GRAY	L	LAVENDER
			O	ORANGE	W	WHITE	(S)	SLATE		

BARD MFG. CO.

4096-119 E