



USE COPPER CONDUCTORS ONLY
SUITABLE FOR AT LEAST 75° C

COMPONENT CODE			
CB1	CIRCUIT BREAKER #1	HC2	HEATER CONTACTOR #2
CB2	CIRCUIT BREAKER #2	HPC	HIGH PRESSURE CONTROL
CC	COMPRESSOR CONTACTOR	IBC	INDOOR BLOWER CAPACITOR
COMP	COMPRESSOR	IBM	INDOOR BLOWER MOTOR
DCC	DUAL CAN CAPACITOR	IBR	INDOOR BLOWER RELAY
DFC	DEFROST CONTROL	LAB	LOW AMBIENT BYPASS CONTROL
EMR	EMERGENCY HEAT RELAY	LAC	LOW AMBIENT CONTROL
ERV	ENERGY RECOVERY VENTILATOR	LPB	LOW PRESSURE BYPASS
FT	FREEZE T-STAT	LPC	LOW PRESSURE CONTROL
GND	EQUIPMENT GROUND	LS	LIMIT SWITCH
H1	HEAT STRIP #1	OFM	OUTDOOR FAN MOTOR
H2	HEAT STRIP #2	PL1	PLUG #1
HC1	HEATER CONTACTOR #1	RAT	RETURN AIR THERMOSTAT
RLB	RELAY LOGIC BOARD	RV	REV. VALVE SOLENOID
RV	REV. VALVE SOLENOID	SK	START KIT
T	TRANSFORMER	TB	TERMINAL BLOCK
TB	TERMINAL BLOCK	TBL	LOW VOLTAGE TERMINAL BLOCK
TBL	LOW VOLTAGE TERMINAL BLOCK	TCO	THERMAL CUTOFF
TCO	THERMAL CUTOFF	TWV	THREE WAY VALVE
TWV	THREE WAY VALVE		

A, B LABELED WIRES CONNECT IF NO OPTIONS USED.
 C MOVE RED WIRE TO 208V TAP FOR 208V OPERATION
 D RED (LOW) BLACK (HIGH) BLUE (MEDIUM) WHERE APPLICABLE

HIGH VOLTAGE		LOW VOLTAGE		ACCESSORY		COLOR CODE														
FACTORY STD.	FIELD	OPTIONAL	FACTORY STD.	FIELD	OPTIONAL	BK	BR	R	O	Y	G	BL	W	V	(PR)	GY	(S)	T	PK	L
—	---	-.-.-	—	---	-.-.-	BLACK	BROWN	RED	ORANGE	YELLOW	GREEN	BLUE	WHITE	VIOLET	PURPLE	GRAY	SLATE	TAN	PINK	LAVENDER

BARD MFG. CO.

4096-127