



USE COPPER CONDUCTORS ONLY  
SUITABLE FOR AT LEAST 75° C

COMPONENT CODE

CB1	CIRCUIT BREAKER #1	HC2	HEATER CONTACTOR #2	RLB	RELAY LOGIC BOARD
CB2	CIRCUIT BREAKER #2	HPC	HIGH PRESSURE CONTROL	RV	REV. VALVE SOLENOID
CC	COMPRESSOR CONTACTOR	IBC	INDOOR BLOWER CAPACITOR	SK	START KIT
CCH	COMPRESSOR CRANKCASE HEATER	IBM	INDOOR BLOWER MOTOR	T	TRANSFORMER
COMP	COMPRESSOR	IBR	INDOOR BLOWER RELAY	TB	TERMINAL BLOCK
DCC	DUAL CAN CAPACITOR	LAB	LOW AMBIENT BYPASS CONTROL	TBL	LOW VOLTAGE TERMINAL BLOCK
DFC	DEFROST CONTROL	LAC	LOW AMBIENT CONTROL	TCD	THERMAL CUTOFF
EMR	EMERGENCY HEAT RELAY	LPC	LOW PRESSURE CONTROL	TWV	THREE WAY VALVE
ERV	ENERGY RECOVERY VENTILATOR	LS	LIMIT SWITCH		
FT	FREEZE T-STAT	DFM	OUTDOOR FAN MOTOR		
GND	EQUIPMENT GROUND	PL1	PLUG #1		
H1	HEAT STRIP #1	RAT	RETURN AIR THERMOSTAT		
H2	HEAT STRIP #2				
HC1	HEATER CONTACTOR #1				

**A**, **B** LABELED WIRES CONNECT IF NO OPTIONS USED. **△** MOVE RED WIRE TO 208V TAP FOR 208V OPERATION **△** RED (LOW) BLACK (HIGH) WHERE APPLICABLE

FACTORY STD.			FIELD			OPTIONAL			COLOR CODE				
HIGH VOLTAGE	————	----	————	----	----	BK	BLACK	Y	YELLOW	V	VIOLET	T	TAN
LOW VOLTAGE	————	----	————	----	----	BR	BROWN	G	GREEN	(PR)	PURPLE	PK	PINK
ACCESSORY	————	----	————	----	----	R	RED	BL	BLUE	GY	GRAY	L	LAVENDER
						O	ORANGE	W	WHITE	(S)	SLATE		

**BARD MFG. CO.**  
4096-130 B