



COMPONENT CODE			
CB1	CIRCUIT BREAKER #1	IBR	INDOOR BLOWER RELAY
CB2	CIRCUIT BREAKER #2	LAB	LOW AMBIENT BYPASS CONTROL
CC	COMPRESSOR CONTACTOR	LAC	LOW AMBIENT CONTROL
COMP	COMPRESSOR	LPB	LOW PRESSURE BYPASS
DCC	DUAL CAN CAPACITOR	LPC	LOW PRESSURE CONTROL
DFC	DEFROST CONTROL	LSC	LIMIT SWITCH
DLT	DISCHARGE LINE THERMOSTAT	DFM	OUTDOOR FAN MOTOR
EHR	EMERGENCY HEAT RELAY	PL1	PLUG #1
GND	EQUIPMENT GROUND	RV	REV. VALVE SOLINOID
H1	HEAT STRIP #1	SK	START KIT TRANSFORMER
H2	HEAT STRIP #2	T	TERMINAL BLOCK
HC1	HEATER CONTACTOR #1	TB	TERMINAL BLOCK
HC2	HEATER CONTACTOR #2	TBL	LOW VOLTAGE TERMINAL BLOCK
HPC	HIGH PRESSURE CONTROL	TCO	THERMAL CUTOFF
HSS	HIGH SPEED SOLINOID		
IBM	INDOOR BLOWER MOTOR		

USE COPPER CONDUCTORS ONLY
SUITABLE FOR AT LEAST 75° C

A **B** LABELED WIRES CONNECT IF NO OPTIONS USED. **C** MOVE RED WIRE TO 208V TAP FOR 208V OPERATION **D** RED (LOW) BLUE (MEDIUM) BLACK (HIGH) WHERE APPLICABLE

		COLOR CODE			BARD MFG. CO.							
		FACTORY STO.	FIELD	OPTIONAL	4096-132							
HIGH VOLTAGE	————	---	---	---	BK	BLACK	Y	YELLOW	V	VIOLET	T	TAN
LOW VOLTAGE	————	---	---	---	BR	BROWN	G	GREEN	(PR)	PURPLE	PK	PINK
ACCESSORY	————	---	---	---	R	RED	BL	BLUE	GY	GRAY	L	LAVENDER
					O	ORANGE	W	WHITE	(S)	SLATE		