



COMPONENT CODE			
CB1	CIRCUIT BREAKER #1	IBR	INDOOR BLOWER RELAY
CB2	CIRCUIT BREAKER #2	LAB	LOW AMBIENT BYPASS CONTROL
CC	COMPRESSOR CONTACTOR	LAC	LOW AMBIENT CONTROL
COMP	COMPRESSOR	LPB	LOW PRESSURE BYPASS
DCC	DUAL CAN CAPACITOR	LPC	LOW PRESSURE CONTROL
DFC	DEFROST CONTROL	LS	LIMIT SWITCH
EHR	EMERGENCY HEAT RELAY	MSR	MOTOR SPEED RELAY
GND	EQUIPMENT GROUND	DFM	OUTDOOR FAN MOTOR
H1	HEAT STRIP #1	PL1	PLUG #1
H2	HEAT STRIP #2	RV	REV. VALVE SOLINOID
HC1	HEATER CONTACTOR #1	SK	START KIT
HC2	HEATER CONTACTOR #2	T	TRANSFORMER
HPC	HIGH PRESSURE CONTROL	TB	TERMINAL BLOCK
IBC	INDOOR BLOWER CAPACITOR	TBL	LOW VOLTAGE TERMINAL BLOCK
IBM	INDOOR BLOWER MOTOR	TCO	THERMAL CUTOFF

USE COPPER CONDUCTORS ONLY  
SUITABLE FOR AT LEAST 75° C

⚠️ ⚠️ LABELED WIRES CONNECT IF NO OPTIONS USED.
 ⚠️ MOVE RED WIRE TO 208V TAP FOR 208V OPERATION
 ⚠️ RED (LOW) BLACK (HIGH) WHERE APPLICABLE
 ⚠️ REMOVE JUMPER FOR OUTDOOR THERMOSTAT

COLOR CODE							
BK	BLACK	Y	YELLOW	V	VIOLET	T	TAN
BR	BROWN	G	GREEN	(PR)	PURPLE	PK	PINK
R	RED	BL	BLUE	GY	GRAY	L	LAVENDER
O	ORANGE	W	WHITE	(S)	SLATE		

HIGH VOLTAGE \_\_\_\_\_  
 LOW VOLTAGE \_\_\_\_\_  
 ACCESSORY \_\_\_\_\_

FACTORY STD. \_\_\_\_\_  
 FIELD \_\_\_\_\_  
 OPTIONAL \_\_\_\_\_

**BARD MFG. CO.**  
 4096-138 A