



USE COPPER CONDUCTORS ONLY
SUITABLE FOR AT LEAST 75° C

⚠ **⚠** LABELED WIRES CONNECT IF NO OPTIONS USED. **⚠** MOVE RED WIRE TO 208V TAP FOR 208V OPERATION **⚠** RED (LOW) BLACK (HIGH) WHERE APPLICABLE

	FACTORY STD.	FIELD	OPTIONAL	COLOR CODE							
HIGH VOLTAGE	————	-----	-----	BK	BLACK	Y	YELLOW	V	VIOLET	T	TAN
LOW VOLTAGE	————	-----	-----	BR	BROWN	G	GREEN	(PR)	PURPLE	PK	PINK
ACCESSORY	————	-----	-----	R	RED	BL	BLUE	GY	GRAY	L	LAVENDER
				O	ORANGE	W	WHITE	(S)	SLATE		

COMPONENT CODE			
CB1	CIRCUIT BREAKER #1	IBR	INDOOR BLOWER RELAY
CB2	CIRCUIT BREAKER #2	LAB	LOW AMBIENT BYPASS CONTROL
CC	COMPRESSOR CONTACTOR	LPC	LOW AMBIENT CONTROL
CCH	COMPRESSOR CRANKCASE HEATER	LPB	LOW PRESSURE BYPASS
COMP	COMPRESSOR	LPC	LOW PRESSURE CONTROL
DFC	DEFROST CONTROL	LS	LIMIT SWITCH
EHR	EMERGENCY HEAT RELAY	DFC	OUTDOOR FAN CAPACITOR
GND	EQUIPMENT GROUND	OFM	OUTDOOR FAN MOTOR
H1	HEAT STRIP #1	OFR	OUTDOOR FAN RELAY
H2	HEAT STRIP #2	PL1	PLUG #1
HC1	HEATER CONTACTOR #1	RV	REV. VALVE SOLINOID
HC2	HEATER CONTACTOR #2	T	TRANSFORMER
HPC	HIGH PRESSURE CONTROL	TB	TERMINAL BLOCK
IBC	INDOOR BLOWER CAPACITOR	TBL	LOW VOLTAGE TERMINAL BLOCK
IBM	INDOOR BLOWER MOTOR	TCO	THERMAL CUTOFF

BARD MFG. CO.
4096-210 F