



COMPONENT CODE			
CB1	CIRCUIT BREAKER #1	IBR	INDOOR BLOWER RELAY
CB2	CIRCUIT BREAKER #2	LAB	LOW AMBIENT BYPASS CONTROL
CC	COMPRESSOR CONTACTOR	LAC	LOW AMBIENT CONTROL
COMP	COMPRESSOR	LPB	LOW PRESSURE BYPASS
DFC	DEFROST CONTROL	LPC	LOW PRESSURE CONTROL
EHR	EMERGENCY HEAT RELAY	LS	LIMIT SWITCH
GND	EQUIPMENT GROUND	DFC	OUTDOOR FAN CAPACITOR
H1	HEAT STRIP #1	OFM	OUTDOOR FAN MOTOR
H2	HEAT STRIP #2	DFR	OUTDOOR FAN RELAY
HC1	HEATER CONTACTOR #1	PL1	PLUG #1
HC2	HEATER CONTACTOR #2	RV	REV. VALVE SOLIDID TRANSFORMER
HPC	HIGH PRESSURE CONTROL	T	TERMINAL BLOCK
IBC	INDOOR BLOWER CAPACITOR	TBL	LOW VOLTAGE TERMINAL BLOCK
IBM	INDOOR BLOWER MOTOR	TCO	THERMAL CUTOFF

USE COPPER CONDUCTORS ONLY
SUITABLE FOR AT LEAST 75° C

△	△	LABELLED WIRES CONNECT IF NO OPTIONS USED.	△	MOVE RED WIRE TO 208V TAP FOR 208V OPERATION	△	RED (LOW) BLACK (HIGH) WERE APPLICABLE
HIGH VOLTAGE			COLOR CODE			
LOW VOLTAGE			BK	BLACK	Y	YELLOW
ACCESSORY			BR	BROWN	G	GREEN
			R	RED	BL	BLUE
			O	ORANGE	W	WHITE
			V (PR)	VIOLET	T	TAN
			GY (S)	GRAY	PK	PINK
				SLATE	L	LAVENDER
						BARD MFG. CO.
						4096-213 C