



COMPONENT CODE			
CB1	CIRCUIT BREAKER #1	LAB	LOW AMBIENT BYPASS
CB2	CIRCUIT BREAKER #2	LAC	LOW AMBIENT CONTROL
CC	COMPRESSOR CONTACTOR	LPB	LOW PRESSURE BYPASS
COMP	COMPRESSOR	LPC	LOW PRESSURE CONTROL
DFC	DEFROST CONTROL	LS	LIMIT SWITCH
EHR	EMERGENCY HEAT RELAY	DFC	OUTDOOR FAN CAPACITOR
GND	EQUIPMENT GROUND	DFM	OUTDOOR FAN MOTOR
H1	HEAT STRIP #1	DMT	OUTDOOR MOTOR THERMOSTAT
H2	HEAT STRIP #2	PL1	PLUG #1
HC1	HEATER CONTACTOR #1	PM	PHASE MONITOR
HC2	HEATER CONTACTOR #2	RV	REV. VALVE SOLINOID
HPC	HIGH PRESSURE CONTROL	T	TRANSFORMER
IBC	INDOOR BLOWER CAPACITOR	TB, TB2	TERMINAL BLOCK
IBM	INDOOR BLOWER MOTOR	TBL	LOW VOLTAGE TERMINAL BLOCK
IBR	INDOOR BLOWER RELAY	TCO	THERMAL CUTOFF

USE COPPER CONDUCTORS ONLY  
SUITABLE FOR AT LEAST 75° C

,   LABELED WIRES CONNECT IF NO OPTIONS USED.			MOVE RED WIRE TO 208V TAP FOR 208V OPERATION			RED (LOW) BLACK (HIGH) BLUE (MED) WHERE APPLICABLE					
			COLOR CODE								
HIGH VOLTAGE	FACTORY STD.	FIELD	OPTIONAL	BK	BLACK	Y	YELLOW	V	VIOLET	T	TAN
LOW VOLTAGE	————	- - - -	----	BR	BROWN	G	GREEN	(PR)	PURPLE	PK	PINK
ACCESSORY	————	- - - -	----	R	RED	BL	BLUE	GY	GRAY	L	LAVENDER
				O	ORANGE	W	WHITE	(S)	SLATE		

**BARD MFG. CO.**  
4096-218 C